Data Sheet | Item Number: 207-1332

Gelbox; Derivaţie; pentru cabluri; cu gel; Seriile 221, 2x73; conectori de max. 4 mm²; fără conectori pentru cutia de joncţiune; Mărimea 2; gri




https://www.wago.com/207-1332













Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332



Note on Packaging Unit (PU) and Subpackaging Unit (SPU):

If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box.

If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- · Can be used immediately and accessed again later
- Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Connection data

Connection 1

Actuation type Locking system

P	hy	'Sİ	cal	d	a	ta
---	----	-----	-----	---	---	----

Width	45,9 mm / 1.807 inci
Height	17,8 mm / 0.701 inci
Depth	33,6 mm / 1.323 inci

Mechanical data

Design	Size 2
Mounting type	Flying leads
Protection type	IPX8
Suitable	für Verbindungsklemmen 4 mm²

Material data

Material data	
Note (material data)	Information on material specifications can be found here
Color	gri
Housing material	Polypropylene
Fire load	0 MJ
Weight	18.4 g

Environmental requirements

2. Transmittan requirements	
Ambient temperature (operation)	-55 +85 °C
Ambient temperature (storage)	0+40°C

Commercial data

ETIM 8.0	EC001170
ETIM 7.0	EC001170
PU (SPU)	48 (4) Buc.
Country of origin	DE
GTIN	4055143998017
Customs tariff number	85389099990



Environmental Product Compliance

RoHS Compliance Status

Compliant, No Exemption

Approvals / Certificates

General approvals



rungsinstitut

Approval	Standard	Certificate Name
VDE	EN 60998	400051938
VDE Prüf- und Zertifizie-		

Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

xml

3.58 KB

docx

20.38 KB

Downloads Documentation **System Description Bid Text** System Description pdf 207-1332 1156.45 KB 207 Series Gel boxes System Description pdf 207-1331 1191.37 KB 207 Series Gel boxes

CAD/CAE-Data	
CAD data	CAE data
2D/3D Models 207-1332	ZUKEN Portal 207-1332

Installation Notes

Close latch securely.

Installation



Open the Gelbox at the side latches.





Re-accessible:

- Open the Gelbox.
- · Remove the gel.
- Rewire with new components.



Place the wired connector in the Gelbox.



Close the Gelbox.

Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332











Lift the flap and pull the cover perforation forward.

Press in the perforation on the sides.

Tear off the cover from the perforation.

As a counter display: Bend the rear flap at the fold, straighten it and fix it in the card-board cut-out



If the flap is not required, tear off from the perforation.

Subject to changes. Please also observe the further product documentation!