

**Testing tools  
VT COMBI PRO**

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany  
 Fon: +49 5231 14-0  
 Fax: +49 5231 14-292083  
 www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LED-Display
- acc. to VDE standard
- high peak voltage strength
- the right tester for every application

**General ordering data**

Type	VT COMBI PRO
Order No.	<a href="#">9918860000</a>
Version	2-pole voltage tester type 1156, Yes - visual + acoustic
GTIN (EAN)	4032248405749
Qty.	1 pc(s).

**Testing tools  
VT COMBI PRO**

**Weidmüller Interface GmbH & Co. KG**  
 Klingenbergstraße 26  
 D-32758 Detmold  
 Germany  
 Fon: +49 5231 14-0  
 Fax: +49 5231 14-292083  
 www.weidmueller.com

**Technical data****Dimensions and weights**

Width	264 mm	Width (inches)	10.394 inch
Height	33 mm	Height (inches)	1.299 inch
Depth	67 mm	Depth (inches)	2.638 inch
Weight	290 g	Net weight	356 g

**Environmental Product Compliance**

REACH SVHC Lead 7439-92-1

**Measuring and testing devices**

AC voltage display	6, 12, 24, 50, 120, 230, 400, 690 V	AC voltage measuring range	6-690 V
Battery type	1.5 V type AAA battery	Continuity test	Yes - visual + acoustic
DC voltage display	6, 12, 24, 50, 120, 230, 400, 690 V	DC voltage measuring range	690 V
Display	LED	Frequency range, max.	400 Hz
Frequency range, min.	16 Hz	Insulation test	8 kV
Measuring range category	CAT III – 690V/CAT IV – 600V	Note	Screw-on, thicker test probes
Peak voltage resistance	8 kV	Protection degree	IP65
RCD circuit breaker	The selectable load enables conscious triggering of a 30 mA RCD circuit breaker	Rated voltage, max.	690 V AC/DC
Rated voltage, min.	6 V	Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)
Working temperature, max.	55 °C	Working temperature, min.	-15 °C

**Classifications**

ETIM 6.0	EC000494	ETIM 7.0	EC000494
eClass 9.0	27-20-03-08	eClass 9.1	27-20-03-08
eClass 10.0	27-20-03-08	UNSPSC	41-11-36-37

**Approvals**

Approvals



ROHS Conform

**Downloads**

Approval/Certificate/Document of Conformity	<a href="#">9918860000_DECLARATION_OF_CONFORMITY.pdf</a>
Brochure/Catalogue	<a href="#">CAT 6 TOOLS 15/16 EN</a>
Product Change Notification	<a href="#">PCN-PW641110-20180410-00-A EN</a> <a href="#">PCN-PW641110-20180410-00-A DE</a>
User Documentation	<a href="#">BANL_manual 2pol Tester</a>

Creation date October 1, 2020 12:35:40 PM CEST

Catalogue status 25.09.2020 / We reserve the right to make technical changes.